

The Village of

Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

April 2024 Report

Work

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up
- Park Bench restoration
- Water Leaks throughout Village
- Plowing and salting as needed.

Water/Sewer

- Checked on a future drainage issue for Neil. Culvert plugging at the Reservoir. We need to create a swale to lower elevation to promote water flow.
- Ransom St Storm drain plugged- fixed
- Manhole complaint- placed barrel on S. Main St until weather is conducive to fixing.
- Removed dead rabbit from N. Main St Sewer.
- Filter cleaning- 2 filters cleaned.
- Camera'd Bergeron's on Elm St- line was found to be in poor condition. They rerouted their sewer to another tap.

Streets

- Met with Salisbury DPW Superintendent regarding road posting. The larger trucks will be off the road until the road posting comes down. 1 Ton trucks will be the only way material is hauled to North Main.
- Met with Pat Race about 24 Paving
- Finished salting and plowing for the season, hopefully.
- Lamberson St- filled in hole from water leak.
- Removed low hanging tree on State St.
- Painted over graffiti on poles throughout the village.
- More banners went up

Garage

- “09” Freightliner- multiple issues- need to consider replacement.
- 3500- nothing new
- 12 Freightliner- has a front-end issue. We are investigating avenues of repair.
- 550- nothing new
- Roller- will be brought in to do repairs shortly
- Loader- nothing new
- Leaf Picker- no new issues
- Sewer Jet- no new issues
- Skid Steer- no new issues
- Excavator- still needs bushings in the bucket. Developed a leak in the ram controlling the dipper arm. Will take off and take the bobcat for repair. Noticed several other rams starting to weep. Guard for Dozer blade broke off. Found broken roller on left side trac, replaced all the rollers on that side. We are waiting on 2 to replace the right side.
- Monthly Fuel Tank Check and inspections
- Snowman-Still has body and frontend issues.
- Back Hoe- no new issues
- Fuel tank Gauges- Buell stopped and started the process of installing- ongoing- still not complete- Again called and made contact- they assured me they were there and I sent pictures showing they were not. They will be looking into

the best way to get the project done hopefully within the next month. - Called again. Was informed the gauges could not be installed due to a stuck fitting on the diesel tank. That issue was resolved as of 4/10/24. Will call 4/11/24 and set appointment for gauges to be installed.

- Cable is still out, still an issue. Called Spectrum on multiple occasions. Apparently, cable at the garage was discontinued. It will need to be rectified by whoever deals with the cable. - Still out
- 60-inch Mower-no new issues
- Water cart- will be sourcing new tires. - working on.
- 71" mower- complete service was done on its return from Stahl's.
- Garage cleaning is ongoing.
- Shared services with Manheim- they borrowed chipper- still out
- 4/11 shared services- going to Middleville- digging test hole to see if there is a water leak.
- Truck books- back dated to the date of my start as Superintendent and they are completed.
- Working on FCC Radio License.
- OGS salt requirements for 24/25 are in.
- State Road permit has been sent.
- R33 permit for Violet Festival is completed with the exception of MOVAC and PD's letter. MOVAC was recontacted as of 4/10/24.

Parks

- Greenway Trail- Hauled in material and filled in wet spots. We laid down millings on about a ¼ of a mile of trail.
- Plowe Park- removed trees finally
- Center Park- gray building – water has been reinstated.
- Little League Field- Power is reconnected. Replaced a toilet, faucet, installed a Sewage pump and installed a tankless hot water unit.
- Beavers-Tricot- no new signs of beaver activity
- Helterline- Garbage's are back in all parks.
- Luther Park- Picked up debris from accident over the weekend. Can discuss- time permitting will get pricing on 2 poles and 1 bench.

North Main St

- All foundations are close to being filled.
- Rick Barnes took down the chimney that Solid Waste was worried about.
- Keeping up with force logs
- Multiple scrap runs have been done
- 3 houses are left to come down. The abatement is being on 128 and 1/30. Started on 4/8/24

To Do:

- Continue to train new employees
- Set up paving and sealing schedule 2024
- Build new bridges at Reservoir.
- Cleaning Filters as required
- Cleaning Reservoir
- Keep trucks serviced and cleaned.
- Cleaning and Organizing Garage
- Burt St- Remove Vegetation
- Add Gutters to Village Hall
- Rehab manholes- South Main St at Faville Ave
- Fix culvert issue at Reservoir
-