

8-5
9/16/24

The Village of Dolgeville

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

September 2024 Report

Water/Sewer

- Reviewed Installation of Water meter with Trainer.
- Checking and clearing of storm drains.
- Looked at LF Reservoir Cleaning.
- Worked on lead and copper survey
- Water pressure complaint @ 53 S. Main St- partially closed valve.
- Sewer complaint on Mckinnley- Our main was running.
- Worked with Neal at Tricot to install a radio on their Meter.
- Investigated buzzing of pipes on Bever St- Nothing found.
- Mowed WWTP and Reservoir
- Patched water job on 167.
- Flushed N. Main St Sewer
- 811 requests for DOT
- Installed 8 Meters throughout village.

- Flushed Spofford Square-plugged sewer resolved.
- In the process of ordering manholes for Brighton Court, Spofford Square and Ransom St.
- Flushed hydrant at Manheim Town Barn.
- Drain at Village Hall- A sink had a slow drain- seems to be working.

Streets

- Storm Cleanup
- Shoulder work on Millers Grove Rd
- Green waste
- Cut back sidewalks throughout village
- Cleared downed trees from Bever Brook.
- Dead tree South Main investigated and turned it over to codes.
- Road signs-put up Vanburen St a 30 MPH that was pushed into traffic. Replaced 6 stop signs and looking into no parking from here to corner due to complaints.
- Striping and Village Hall and Kinney's
- Chip Sealing on Millers Grove Rd.
- Put up new Banners and moved some around.
- Flags went up and back down again.
- Flowers are all down.
- Cold patching Main and Elm
- Replaced Barrier N. Side of State St at trail head.

Garage

- "09" Freightliner- nothing new
- 12 Freightliner- Currently at Winkler's for Kingpins.
- 550- nothing new
- Roller- nothing new
- Loader- nothing new
- Leaf Picker- moved into garage and has oil change and was greased and test fired and is ready for season.
- Leaf box was brought in, broken welds repaired and bolts replaced.
- Sewer Jet- no new issues
- Skid Steer- no new issues
- Excavator- still has a random overheating issue
- Monthly Fuel Tank Check and inspections
- Snowman-plow harness is in the process of being installed.
- Back Hoe- nothing new
- Fuel tank Gauges- ok
- Cable is still out, still an issue. Called Spectrum on multiple occasions. Apparently, cable at the garage was discontinued. It will need to be rectified by whoever deals with the cable. - Still out
- 60" Mower- no new issues
- Water cart- taken out of service for year
- 71" mower-no new issues
- Garage cleaning is ongoing.
- Shared services with Manheim- they borrowed chipper- still out

- Working on FCC Radio License- paperwork completed.
- Back end of the Garage roof became detached during a wind storm causing damage. Insurance has been notified. Mohawk Valley Coatings has been called, Quote is in. They did the last roof repair; it makes sense to continue to use their system. Repair Eminent.
- Helped PD with 601. We jumped it on several occasions, oil has been changed. It has a charging issue.

Parks

- Greenway Trail- Barriers are up.
- Plowe Park- Mowed and Maple Tree has been removed.
- Center Park- Mowing done. Have a place for Camera just need time to dig the trench for the electrical.
- Little League Field- nothing new
- Helterline- Tree was removed.
- Luther Park- Mowed.

North Main St

Nothing new

To Do:

- Continue to train new employees
- Build new bridges at Reservoir.
- Cleaning Filters as required
- Keep trucks serviced and cleaned.
- Cleaning and Organizing Garage

- Burt St- Remove Vegetation
- Add Gutters to Village Hall- 9/22/24 Gutters scheduled for installation. All Vehicles will need to be away from the front of the building.
- Fix culvert issue at Reservoir
- Ditching throughout the Village
- Cut back road edges
-