

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

10-1
8/19/24

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JULY 13, 2024 to AUGUST 15, 2024

1. PERMIT COMPLIANCE FOR JUNE 2024

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance and summer grounds work
- Annual snail removal from aeration tank with assistance from DPW
- Replaced refrigerator in laboratory
- Replaced UPS in Aeration Building Control Panel
- Gas mixer (2007) on the digester is not working; in the process of troubleshooting; manufacturer does not have dedicated service technicians, authorized dealer, nor do they have parts in stock.
- 2 Gas unit heaters need replacing – ongoing

3. PRETREATMENT PROGRAM

See Village Engineer's report. Recommend contracting with C.T. Male. Funds were allocated for this task in the current budget.