

8-3
7/15/24

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JUNE 13, 2024 to JULY 12, 2024

1. PERMIT COMPLIANCE FOR MAY 2024

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance and summer grounds work
- Replaced pH meter in laboratory
- 2 Gas unit heaters need replacing, getting quote
- 1970 Laboratory refrigerator no longer works, will order new one

3. PRETREATMENT PROGRAM

RFQ for SPDES Consultant advertised June 28.