

8-1
3/18/24

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT FEBRUARY 8, 2024 to MARCH 13, 2024

1. PERMIT COMPLIANCE FOR JANUARY 2024

No permit violations to report.

2. MAINTENANCE

- Normal Preventive Maintenance
- Backup high level alarm float in wet well failed; replacement installed by J&A Electric 2/28/24
- 2 Gas unit heaters need replacing, getting quote

3. PESH INSPECTION – (Update)

In 2023, the WWTP had 2 NYSDOL PESH inspections (March and June). As a result, 2 separate notices of violation were issued, one in September and one on 1/17/24. The only remaining item from the September notice is fall protection on the roof at the waste gas burner, deadline was extended to June 1. Anticipated that we will have a proposed design and cost estimate for review at this meeting.

4. NYSDEC INSPECTION

NYSDEC Engineer visited the plant for the annual plant inspection on February 23, 2024. Inspection report is expected this month.

5. ASSISTING WITH DWSP2

Herkimer-Oneida Comprehensive Planning Program is our technical assistance provider for the Drinking Water Source Protection Program (DWSP2). A kickoff meeting was held with them on February 27, 2024. Key stakeholders from the Village and the Town of Salisbury will have their first meeting March 27, 2024.