

9-5
5/20/24

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT APRIL 12, 2024 to MAY 15, 2024

1. PERMIT COMPLIANCE FOR MARCH 2024

SPDES permit requires 85% removal for BOD and TSS. Due to rain-attributable inflow and infiltration (I/I) in March, the plant did not meet that requirement and also exceeded the permit limit of 1.0mgd average flow. The plant removed 79% BOD and 80% TSS and had an average flow of 1.1mgd.

2. MAINTENANCE

- Normal Preventive Maintenance
- Annual service on Chlorinators/Sulfonators
- Installing KeeGuard railing on roof of Admin Building
- 2 Gas unit heaters need replacing, getting quote

3. PESH INSPECTION – (Update)

Kee Safety roof guard system was ordered. The system is mostly installed. We anticipate getting the last shipment of parts this week. The PESH compliance deadline for this work is June 1. There should be no problem meeting the deadline.

4. OPERATOR TRAINEE

Promotion to Assistant Operator is anticipated in July or August.