

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

9-1

10/21/24

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT SEPTEMBER 12, 2024 to OCTOBER 17, 2024

1. PERMIT COMPLIANCE FOR AUGUST 2024

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance
- 2 Gas unit heaters need replacing – ongoing
- Bearing replaced on Penn Valley pump
- Aqualogics replaced output card on PLC for flow signal to main building
- Trojan Energy replaced low water cutoff switch on boiler

3. OHSWA

Waste profile submitted to Oneida-Herkimer Solid Waste Authority and approved.
Disposal of dewatered sludge authorized until September 2027.

4. BRAYTON COURT SEWER

DPW will begin work to install manhole week of Oct. 21.

5. SAFETY

WWTP staff completed annual respirator fit and pulmonary function testing.

6. LCRR

Assisting Neal with LCRR compliance

7. EPA WATER TA

Neal and I submitted an interest form to EPA for their programs related to water and sewer engineering services and funding source assistance. This is a free service providing engineering for preliminary engineering reports needed to apply for project funding. Technical assistant teams then help communities seek funding for their projects. We are waiting to hear back.