

8-2
9/16/24

VILLAGE OF DOLGEVILLE
WASTEWATER TREATMENT FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT AUGUST 16, 2024 to SEPTEMBER 11, 2024

1. PERMIT COMPLIANCE FOR JULY 2024

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance
- Update: reported last month that digester gas mixer was down, it is operational for now. PLC will be upgraded and possibly replace/rebuild gear reducer.
- 2 Gas unit heaters need replacing – ongoing

3. SPDES SUBMISSIONS

As required by Village SPDES permit, the annual Mercury Minimization Plan and Fast Report on Industrial Users were submitted to NYSDEC on 8/21/24.

4. INDUSTRIAL PRETREATMENT

Had kickoff meeting 9/10/24 with C.T. Male to begin work on pretreatment program and headworks analysis.

5. BRAYTON COURT SEWER

Chet reviewed and approved application/plans submitted by resident at 5 Brayton Ct. to connect to the village sewer system. Since the existing sewer on Brayton Ct only has a cleanout at the end of the line, Chet, Dave and I are planning for a full-size manhole to be installed by the Village DPW to allow the new connection and to make the line more accessible for maintenance and televising. Existing laterals will be tied into the new manhole or reconnected to the main. We will communicate with residents of that street as work progresses to keep them informed if any service interruptions are anticipated. The work is expected to be performed in the next month or so.

6. MAIN ST. SEWER PROJECT

Resolution for bidding project, this meeting.