

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for June 17th, 2024

Water Plant

- 1) Second Quarter DBPs sample were collected on 5/8/24, results for Haloacetic acids were 59.6 ug/l just under the limits of 60 ug/l. Bring our 4-quarter average to 67.35 ug/l. Our next sample in August will need to be below 93 ug/l to get us out of violation,
- 2) DOH has issued violation notice for the second quarter Haloacetic acid, public notification was mailed 6/6/24. Will be expecting another notice sometime in July.
- 3) DOH has also issued a violation notice for failure to have a certified assistant operator, notification must be made in 1 year. I spoke to Billy Viccarelli St Johnsvilles IIA water operator, we are willing to work together to satisfy the needs DOH. The 2 Village Boards need to iron out the agreement.
- 4) Met with Dan Cecconi from Little Falls, I would like hire him on part time to continue his training for IIA certification, take on the Lead & Copper rule, help with meter installation and begin to learn our system.
- 5) Working on a list of commercial customers that require backflow prevention as requested by DOH.
- 6) Water Meters were delivered, waiting for the radios before we start installation.
- 7) Wright-Pierce (engineers for the IDA) are planning flow test on 4 fire hydrants Thursday this week.
- 8) Caulfield Development cost recovery? DOH hopes to finish plan reviews June.
- 9) As of this report I have no updates from DEC on the logging issue. Continue to have elevated raw water turbidities during heavy rain events, as reflected in the number of filter cleanings.
- 10) Attended regular meeting for Source Water Protection Program.
- 11) Any questions or concerns feel free to call, text or Email.

Attachments

- 1) April, water plant flow report.
- 2) News article on Lead & Copper Rule Revision (LCRR).