

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT JANUARY 16, 2025 to FEBRUARY 13, 2025

1. PERMIT COMPLIANCE FOR DECEMBER 2024

All limits, levels and monitoring requirements were met.

Annual permit-required Inflow and Infiltration report submitted to NYSDEC on 1/24/25.

Annual permit-required Water Treatment Chemical form submitted to NYSDEC on 1/22/25.

2. MAINTENANCE

- Normal Preventive Maintenance
- Snow removal, snow removal, more snow removal
- 2 Gas unit heater replacements, 1 unit repair – Work completed by Lynch Heating & Cooling
- Blower motor #2 for gas storage bubble needs replacing. Order placed.
- Requested warranty exterior light replacement for fixture that was installed in 2023.

3. EPA WATER TA

SU-EFC rep. Susan McGrattan met with us on 2/6 to go over the draft infrastructure project priorities and funding opportunities developed from our initial meeting and document review. Will keep the Board updated on any progress and next steps. Since that meeting, the 2025 GIGP grant round has opened up. We have asked Susan to review the application and help us submit for water meter program expansion. More information will hopefully be available for Board meeting. Application is due April 11.

4. PRETREATMENT PROGRAM/HEADWORKS ANALYSIS

CT Male has been providing technical assistance on industrial discharge permitting & well as planning phases of the headworks analysis.

5. MAIN ST SEWER PROJECT

Preconstruction meeting is anticipated to be held week of 2/24 or 3/3.