

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT APRIL 16, 2025 to JUNE 10, 2025

1. PERMIT COMPLIANCE FOR APRIL 2025

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance and yardwork
- Requested warranty exterior light replacement for fixture that was installed in 2023.
- Ordered/received parts to rebuild skimmer arms on final clarifiers this summer (work will be scheduled during dry weather)
- Annual Chlorinator and Sulfonator service by Kleen H2O on 4/28/25
- Replaced motor on gas bubble blower #2 on 5/12- 5/13/25
- Feed line from digester plugged 5/22/25, resolved
- Leveling and seeding portion of yard
- Tailored Computer Care set up system for backing up computer files
- Rebuilt Penn Valley Pump

3. PRETREATMENT PROGRAM/HEADWORKS ANALYSIS

Working with CT Male on beginning the Headworks Analysis. Village staff will coordinate/conduct sampling. CT Male is also assisting with review of the engineering report submitted by Gehring Tricot for upgrades to their pretreatment system.

4. MAIN ST SEWER PROJECT

See Village Engineer summary

5. NYRWA ENERGY ASSESSMENT PROGRAM

A representative from NYRWA visited the plant on 6/11/25 to conduct an energy assessment. A report will be sent to us in July/August with any ways that they identify savings could be realized.

5. RUSTIC TIES – NEW CONNECTION

See Village Engineer summary

6. GIGP GRANT SUBMITTED – WATER METERS (No update)

7. NYSDOL HAZARD ABATEMENT BOARD APPLICATION (No update)