
WRRF report

From amowers@villageofdolgeville.gov <amowers@villageofdolgeville.gov>

Date Fri 5/16/2025 9:40 AM

To 'Mary Puznowski' <mayorpuznowski@villageofdolgeville.gov>; 'Brian Randall' <trusteerandall@villageofdolgeville.gov>; 'Robert Dyer' <trustedyer@villageofdolgeville.gov>; 'Marilyn Williams' <trusteewilliams@villageofdolgeville.gov>; 'Robert Gridley' <trusteegridley@villageofdolgeville.gov>; tchmielewski@villageofdolgeville.gov <tchmielewski@villageofdolgeville.gov>; akraszewski@villageofdolgeville.gov <akraszewski@villageofdolgeville.gov>; cszymanski@villageofdolgeville.gov <cszymanski@villageofdolgeville.gov>

 2 attachments (248 KB)

03SPDESMAR2025.pdf; NY0024554RONCMarch2025.pdf;

Good afternoon,

I needed to take a few days of this week to be with my father at the hospital so apologize for the late and incomplete report.

I do not have a summary this month but have attached the March 2025 DEC report and non-compliance report. I will provide operations and maintenance updates with next month's report.

Each March and April when there is snow melt and spring rain events, the flows at the treatment are heavily influenced by inflow and infiltration that increase our total flows over the 1.0mgd monthly average limit. The excessive "clean" water coming into the plant also creates removal efficiency violations. All concentration and loading limits were met.

During the month of March we reported 3 violations.

- Percent removal efficiency BOD
- Percent removal efficiency Total Suspended Solids
- Flow

My required report for these violations is attached and was provided with my monthly reporting to DEC.

If you have questions about the violations or the report, please let me know.

Thank you,

Amy

Amy Mowers
Chief Operator
Village of Dolgeville WRRF
(315) 429-8549