

THE VILLAGE OF DOLGEVILLE

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

~~June~~ 2025 Report

July

Work

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up
- Park Bench restoration
- Water Leaks throughout Village

Water/Sewer

- Neal's sump and Tree removed
- Flushed North Main St Sewer

- Water break at 97 N. Main St-Wall collapsed during excavation and it sheared the corporation off. Carver was able to unscrew the remainder; new incorporation was found at garage and installed.
- Started painting hydrants
- Water Leak at Elm St/Main. 10-inch wrap clamp supplied.
- Sweeper sent to Waste Water to clean solids contact tank(snails).
- Capped old hydrant spur at Elm St.
- Hauled #2 stone to Reservoir and spread.
- Water complaint on S. Helmer- Water was entering driveway at the address. We repaired driveway apron to prevent water from entering the property.
- Valve Box complaint- Spencer St-needs significant repair.

Streets

- Reset Manholes and Storm drains at Tricot, Ransom St, Lamberson, and everywhere we paved.
- Finished and cleaned rebates.
- Filled water dig on Helmer Ave and West State St.
- Fixed no parking signs on Helmer Ave

- Finished paving throughout Dolgeville for the 2025 season.
- Shared Services for Paving with Manheim, Salisbury, and Oppenheim.
- Touched up all paving areas throughout the Village.

Garage

- “09” Freightliner- No new issues. Truck needs replacement.
- 3500- check engine light is on from the Evap code. Has a tail light out.
- 12 Freightliner- no new issues
- 550- no new issues
- Roller- new fuel filter and new fuel lines due to crack in the line.
- Loader-blew a hydraulic line and was repaired
- Leaf Picker- no new issues
- Sewer Jet- no new issues
- Skid Steer-no new issues
- Excavator- no new issues
- Monthly Fuel Tank Check and inspections
- Back Hoe- has an overheating issue
- Army Truck/530- no new issues
- Fuel tank Gauges- ok

- 60” Mower-has a charging issue. We believe it to be a rectifier issue. One has been ordered.
- Water cart- out of service for the season
- 71” mower-no new issues
- John Deer Tractor- no new issues
- F350- no new issues
- Garage cleaning is ongoing.
- Manheim borrowed the lift and is still out.
- New tire machine- no issues
- Cleaning and Organizing water and sewer rooms.
- Village Hall-
- 602-
- Trailer- no new issues
- Contacted FW Web about training of hydrant
- Set up summer kid for work.
- Ordered trailer
- 603 is on Auctions International along with the Bus and a box of assorted plumbing fittings.
- Shared service with Little Falls-borrowed the cleaning implement for the reservoir- It has been returned.

Parks

- Center Park-
- Mowing of all parks weekly as needed.
- Mowed Trails

- Tree clean up at Plowe Park and we are working on stump removal.
- Meeting with electricians about power replacement/upgrade to Plowe Park.