

THE VILLAGE OF DOLGEVILLE

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

November 2025 Report

Work

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up
- Park Bench restoration
- Water Leaks throughout Village

Water/Sewer

- Updated hydrant billing
- Water turn Ons
- Replaced valve top-Main and Winton
- Cleaned up water rooms

- Lead and Copper Paperwork
- Installed yard hydrant at Helter line Park
- Purchased new locks for yard hydrants
- Repaired Hydrant on Winton Lane
- Located Winton Lane Fire hydrant valve, installed a riser and cold patched.
- Moved curb stop 68 North Main St
- Finished Lead and Copper digs on Main St.
- Investigated empty lot on Ransom St and found water service to lot (no house)
- Turned over lead and Copper paperwork to Amy.
- Cold patched water digs.
- Cleaned Curb stop- 7 Howard St per home owner request.
- Prepared hydrant on State Rt 29
- Repaired Winton Lane water valve after Halloween.
- Raised Fire Hydrant- South Main St- Slawson/Helmer
- Ordered 18-inch extension stem for Spencer St hydrant
- Met with Rawlings about Water meter
- Helped Neal with faulty water meter at laundromat.
- Shut off Green Acres and disconnected water meter.

Streets

- Green waste- for another 2 weeks, same with leaves.
- Cold patching throughout the Village
- Took tires to Manheim
- Picked up garbage container from Winton Lane and removed garbage. Called County waste to pick them up.
- Resubmitted mine paperwork
- Pushed off green waste and managed debris piles
- Set out pumps for Carver during heavy rain events-1 near Napa and 1 near Elm St
- Cleared storm drains
- Faulty storm-drain on S. Main now working.
- National Grid paperwork done for decorations on poles
- Checked roads and first call in for the season for salt.

Garage

- “09” Freightliner- Completed filter change, worked on tail lights, tested salt chain and spinner and oiled chain. Put wing on. Truck needs replacement.

- 3500- check engine light is on from the Evap code. Oil changed completed, cleaned truck, greased and cleaned inside cab.
- 12 Freightliner- Created new tiedowns for salter and put wing on and adjusted.
- 550- Replaced tie rod end, aligned, sent to Brown's Ford for Transmission issues and Transmission was replaced.
- Roller- nothing new
- Loader- discovered a crack in the windshield
- Leaf Picker- Welding repairs to the power unit, fixing cracks and worn parts
- Sewer Jet- nothing new
- Skid Steer- nothing new
- Excavator- nothing new
- Monthly Fuel Tank Check and inspections
- Back Hoe- nothing new
- Army Truck/530- trying to source a new driver door glass. Tighten belts and replaced 1 belt out of stock and fixed belt squeal issue
- Fuel tank Gauges- ok
- 60" Mower- nothing new
- Water cart- out of service for the season
- 71" mower- nothing new
- John Deer Tractor- nothing new
- F350-nothing new
- Garage cleaning is ongoing.
- Manheim borrowed the lift and is still out.
- New tire machine- no issues
- Cleaning and Organizing water and sewer rooms.

- 602- had oil change completed and had 4 tires installed
- Trailer- in use
- Rearranged garage for winter use, cleaned inside of garage doors
- Village Hall-Found leak in Village Hall roof, contacted multiple contractors for pricing, discovered it is a prevailing wage job. Required paperwork filled out and we are waiting for quotes to come back.

Parks

- Center Park- repaired driveway and winterized the gray building.
- Mowing as needed
- Mowed Trails as needed-barriers back in place
- Plowe Park- clipped remaining tree roots, top soiled and seeded
- Blowing leaves out of park as needed.