

9-1  
8/18/25

VILLAGE OF DOLGEVILLE  
WATER RESOURCE RECOVERY FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD  
RE: MONTHLY REPORT JULY 18, 2025 to AUGUST 14, 2025

**1. PERMIT COMPLIANCE FOR JUNE 2025**

All limits, levels and monitoring requirements were met.

**2. MAINTENANCE**

- Normal Preventive Maintenance and yardwork.
- Aeration tank drained/snail removal/cleaned & inspected membrane diffusers
- Requested warranty exterior light replacement for fixture that was installed in 2023 (scheduled for 8/19).
- P.O. approved (\$7500)- VAREC for evaluation of gas handling system, will be scheduled soon.

**3. PRETREATMENT PROGRAM/HEADWORKS ANALYSIS (no update)**

Headworks analysis is on hold due to construction project. We will evaluate at the completion of the project. The characteristics of our influent is expected to change with I/I being removed from the system.

Continued work by CT Male reviewing plans for upgrades to pretreatment system at Gehring Tricot. Further testing is being conducted.

**4. MAIN ST SEWER PROJECT**

See Village Engineer summary

**5. NYRWA ENERGY ASSESSMENT PROGRAM (No update)**

A representative from NYRWA visited the plant on 6/11/25 to conduct an energy assessment. A report will be sent to us in July/August.

**5. RUSTIC TIES – NEW CONNECTION (No update)**

**6. GIGP GRANT SUBMITTED – WATER METERS**

Village was selected for expansion of water meters to all customers. See Village Engineer and Water summaries.

**7. NYSDOL HAZARD ABATEMENT BOARD APPLICATION (No update)**