

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT OCTOBER 16, 2025 to NOVEMBER 13, 2025

1. PERMIT COMPLIANCE FOR SEPTEMBER 2025

- All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance and yardwork.
- VAREC site visit Oct. 27 for digester gas handling system evaluation; recommendation report expected by end of November.
- Waiting on quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor
- Disinfection system shutdown for the season (May 31-Oct. 31)

3. COMP ALLIANCE FOLLOW-UP

After further correspondence regarding the former loading dock, a guardrail system is not needed at this time. If dock is used in the future, will need fall protection added. Signs were placed per the advisory recommendation dated 9/10/2025.

4. PRETREATMENT PROGRAM

Proposed pilot study for additional pretreatment at Gehring Tricot was submitted on October 28, 2025 to the NYSDEC for approval.

5. MAIN ST SEWER PROJECT

See Village Engineer summary