

7-9
10/20/25

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT SEPTEMBER 11, 2025 to OCTOBER 15, 2025

1. PERMIT COMPLIANCE FOR AUGUST 2025

- All limits, levels and monitoring requirements were except 7-day fecal coliform. Noncompliance report for 08/20/25 attached.
- Notice of Violation

2. MAINTENANCE

- Normal Preventive Maintenance and yardwork.
- Avanti Controls onsite 10/15/25 to troubleshoot bar screen heat trace, replacement thermostat and heat trace will be needed

3. PRETREATMENT PROGRAM

Meetings, coordinated efforts, and pilot study review for additional pretreatment at Gehring Tricot.

4. MAIN ST SEWER PROJECT

See Village Engineer summary