

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT AUGUST 15, 2025 to SEPTEMBER 10, 2025

1. PERMIT COMPLIANCE FOR JULY 2025

- All limits, levels and monitoring requirements were met.
- Submitted required Fast Report on Significant Industries and Mercury Minimization Plan annual reporting to NYSDEC.

2. MAINTENANCE

- Normal Preventive Maintenance and yardwork.
- Final Clarifier #1 drained for cleaning and replacement of skimmer heads
- Ordered replacement parts for primary clarifier #2
- 3-yr Milton CAT service contract – P.O. for Board approval

3. PRETREATMENT PROGRAM/HEADWORKS ANALYSIS

Continued work by CT Male reviewing plans for upgrades to pretreatment system at Gehring Tricot. Further evaluation and design are progressing.

P.O. for continued services by C.T. Male for Board review and approval this meeting.

4. MAIN ST SEWER PROJECT

See Village Engineer summary

5. NYRWA ENERGY ASSESSMENT PROGRAM

Representative from NYRWA will be delivering the report 9/11/25. Findings will be discussed with the Board at the meeting.

5. RUSTIC TIES – NEW CONNECTION (No update)

6. WATER/SEWER RATE RESTRUCTURING

Water/sewer rate schedule will need to be adjusted once water meters are installed. Through the Village's participation in the EPA Water TA program, a consultant will be assigned to provide technical assistance, at no cost to the Village, to evaluate and restructure the rate schedule.

7. HELMER AVENUE – SANITARY SEWER MAIN BLOCKAGE

9/6/2025 A sewer main blockage on Helmer Avenue between Elm and State St was cleared by DPW. The cause of the plug was wipes that are being discharged to the sewer. No Wipes in the Pipes flyers and a letter were distributed to residents in that area so that they are made aware that wipes can not be flushed.