

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for August 18th, 2025

Water Plant

- 1) Assisting as needed with main St. Sewer and N. Main st water project. Attempting to identify public side of water service line.
 - 2) Quarter Haloacidic acid sample taken 8/13/252.
 - 3) Plans set to clean the Reservoir on Tuesday 8/19/25 if all goes well.
 - 4) Planning Lead & Copper sampling after reservoir cleaning.
 - 5) Timber sale, no updates
 - 6) Water Meters, grant exception and resolution.
 - 7) Any questions or concerns feel free to call, text or Email.
-

Attachments

- 1) July, water plant flow report.

Respectfully, Neal A. Winkler, Water Plant Operator.

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Jul-25												
1	450,725	469,169	0.01	0.033	0.179	1	0.33	0.089	1.026	1/150	8	
2	469,679	465,609	0.10	0.033	0.177	3	0.41	0.111	0.986	0/143	8	
3	460,143	439,600	0.00	0.034	0.161	2	0.49	0.087	0.940	134	9	
4	444,694	425,270	0.00	0.033	0.154	1	0.91		1.043	123	11	
Sat. 5	442,710	424,036	0.00	0.034	0.146	0	0.91		1.184	113	10	
Sun. 6	451,323	459,856	0.00	0.032	0.134	0	0.97		1.094	105	8	
7	593,230	661,893	0.00	0.032	0.129	12	0.95	0.104	0.993	98	7	0.74
8	611,560	585,813	0.50	0.031	0.137	12	0.54	0.118	0.922	88	10	
9	590,664	589,579	0.00	0.032	0.131	6	0.77	0.114	1.026	76	12	
10	602,616	610,114	0.00	0.030	0.133	7	0.52	0.104	1.206	64	12	
11	610,697	598,273	0.00	0.029	0.135	9	0.31	0.121	1.131	53	11	
Sat. 12	531,323	426,142	0.00	0.030	0.131	3	0.80		1.115	42	9	
Sun. 13	504,613	435,321	1.00	0.028	0.269	0	1.03		1.245	31	11	
14	547,275	599,719	0.75	0.029	0.243	1	1.10	0.098	1.184	21	10	0.38
15	578,785	608,856	0.00	0.029	0.166	4	0.52	0.114	1.122	10	11	
16	629,783	648,434	0.00	0.028	0.152	10	0.28	0.124	1.049	<7/145	11	
17	632,113	618,865	0.00	0.028	0.140	11	0.62	0.093	1.029	132	13	
18	640,409	633,392	0.20	0.036	0.163	14	0.27	0.119	1.083	132	13	
Sat. 19	546,497	442,247	0.00	0.029	0.134	5	1.02		1.197	119	13	
Sun. 20	505,226	455,441	0.00	0.028	0.129	0	0.99		1.247	109	10	
21	562,464	630,985	0.00	0.027	0.124	1	0.57	0.101	1.061	101	8	0.86
22	634,994	665,879	0.00	0.026	0.120	8	0.58	0.101	1.067	91	10	
23	639,128	658,434	0.00	0.026	0.116	12	0.61	0.098	1.028	81	10	
24	649,498	613,759	0.00	0.025	0.116	14	0.74	0.089	0.998	71	10	
25	628,972	609,205	0.00	0.025	0.121	10	0.24	0.112	0.974	61	10	
Sat. 26	541,563	438,729	0.01	0.026	0.119	2	0.98		1.009	51	10	
Sun. 27	511,335	417,644	1.00	0.025	0.121	0	0.99		1.139	41	10	
28	532,728	564,577	0.20	0.028	0.330	1	1.15	0.103	1.211	30	11	0.63
29	590,439	620,181	0.00	0.029	0.178	6	0.72	0.106	1.107	19	11	
30	617,773	638,061	0.00	0.028	0.144	7	0.29	0.121	0.974	8	11	
31	646,302	641,162	0.20	0.028	0.127	13	0.50	0.099	0.947	<1/149	10	
Total	17,399,261	17,096,245	3.97	0.911	4.759	175	21.110	2.326	33.337	1,872	316	2.61
Average	561,266	551,492		0.029	0.154	6	0.68	0.106	1.075	72	10.2	0.65