

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for September 15th, 2025

Water Plant

- 1) Assisting as needed with main St. Sewer and N. Main st water project. Attempting to identify public side of water service line.
- 2) Working BP excavating on water line relocation under Beaver Brook.
- 3) Quarter Haloacidic acid sample taken 8/13/25, THMs results 29.9, 4 quarter average 36.9 limit is 80. Haa5s results 34.4, 4 quarter average 37.38 limit is 60.
- 4) Reservoir on Wednesday 8/20/25 went very well.
- 5) Planning Lead & Copper sampling this week.
- 6) Timber sale, no updates
- 7) Any questions or concerns feel free to call, text or Email.

Attachments

- 1) August, water plant flow report.
- 2) Disinfection By Products spread sheet

Respectfully, Neal A. Winkler, Water Plant Operator.

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Aug-25												
1	581,764	530,180	0.75	0.030	0.242	9	0.56	0.112	1.078	137	12	
Sat. 2	499,468	407,898	0.00	0.029	0.171	2	0.80		0.982	127	10	
Sun. 3	482,014	417,110	0.00	0.029	0.131	0	0.74		1.071	117	10	
4	526,123	565,683	0.00	0.029	0.115	1	0.43	0.103	1.121	107	10	0.43
5	559,885	565,263	0.00	0.028	0.116	5	0.68	0.063	1.099	97	10	
6	585,943	606,384	0.00	0.028	0.111	5	0.28	0.108	1.088	87	10	
7	590,731	574,301	0.00	0.028	0.109	7	0.78	0.081	1.035	77	10	
8	594,925	585,610	0.00	0.028	0.110	7	0.48	0.114	1.037	67	9	
Sat. 9	538,899	456,120	0.00	0.028	0.108	3	0.97		1.039	57	10	
Sun. 10	511,647	462,877	0.00	0.028	0.111	0	1.00		1.177	47	9	
11	564,870	627,471	0.00	0.029	0.111	1	0.98	0.068	1.131	37	9	0.81
12	645,105	703,476	0.00	0.029	0.109	8	0.63	0.089	1.011	31	9	
13	661,647	617,121	0.00	0.029	0.109	13	0.34	0.107	0.938	22	9	
14	648,293	666,815	0.00	0.031	0.118	10	0.69	0.077	0.967	12	10	
15	653,117	609,849	0.00	0.029	0.114	13	0.41	0.121	0.989	1	11	
Sat. 16	564,009	481,061	0.00	0.024	0.115	4	0.94		1.017	0/141	10	
Sun. 17	525,640	473,363	0.00	0.024	0.112	0	1.00		1.076	132	9	
18	557,268	577,405	0.00	0.024	0.114	0	0.92	0.069	1.085	122	10	
19	575,261	572,219	0.00	0.024	0.113	2	0.56	0.091	1.034	112	10	
20	584,252	618,924	0.40	0.024	0.188	3	0.33	0.104	1.011	103	9	
21	596,807	580,393	0.40	0.024	0.157	6	0.66	0.067	0.981	94	9	
22	575,019	561,964	0.00	0.024	0.509	3	0.37	0.096	0.909	85	9	
Sat. 23	527,036	442,483	0.00	0.024	0.203	2	0.80		0.895	77	8	
Sun. 24	509,476	421,914	0.01	0.023	0.120	0	0.80		1.029	68	9	
25	524,294	650,845	0.50	0.023	0.194	4	0.80	0.069	0.963	60	8	
26	601,940	608,114	0.01	0.024	0.128	5	0.54	0.081	0.915	51	9	
27	611,433	611,313	0.01	0.024	0.102	7	0.86	0.097	0.895	40	9	
28	615,484	589,373	0.00	0.024	0.092	8	0.85	0.151	1.037	29	11	
29	586,336	578,973	0.20	0.024	0.094	5	0.46	0.121	1.095	18	11	
Sat. 30	531,616	428,968	0.00	0.024	0.097	1	1.12		0.998	9	9	
Sun. 31	510,274	426,758	0.00	0.024	0.092	0	1.09		1.054	0/150	9	
Total	17,640,576	17,020,228	2.28	0.814	4.315	134	21.870	1.989	31.757	2,023	297	1.24
Average	569,051	549,040		0.026	0.139	4	0.71	0.095	1.024	70	9.6	0.62