

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Sep-25												
1	512,510	445,339	0.00	0.024	0.097	0	0.91	0.083	1.040	<1/142	9	
2	575,102	655,653	0.00	0.024	0.099	2	0.97	0.083	1.066	133	9	0.81
3	640,862	645,540	0.00	0.024	0.104	9	0.65	0.094	0.952	123	10	
4	622,685	693,208	0.00	0.024	0.091	10	0.57	0.102	1.033	114	9	
5	513,348	669,379	0.90	0.024	0.311	22	0.71	0.083	0.994	104	10	
Sat. 6	561,915	426,473	0.00	0.026	0.186	6	0.90		0.883	92	12	
Sun. 7	505,711	437,664	0.20	0.027	0.147	0	0.87		1.015	82	10	
8	547,230	580,609	0.00	0.026	0.126	1	0.89	0.068	1.119	72	10	0.46
9	576,501	596,160	0.00	0.026	0.121	4	0.72	0.118	1.106	62	10	
10	593,895	589,480	0.00	0.026	0.113	7	0.56	0.127	1.101	52	10	
11	607,745	621,893	0.00	0.026	0.102	6	0.87	0.107	1.086	42	10	
12	587,082	531,467	0.00	0.026	0.106	7	0.61	0.126	1.046	32	10	
Sat. 13	521,829	422,432	0.00	0.026	0.100	0	1.10		1.096	22	10	
Sun. 14	514,385	441,997	0.00	0.027	0.104	0	1.08		1.037	15	7	
15	551,010	583,301	0.00	0.026	0.094	1	0.95	0.082	0.981	7	8	0.45
16	584,503	579,895	0.00	0.026	0.097	3	0.46	0.121	1.063	<2/149	10	
17	576,897	557,054	0.00	0.027	0.096	3	0.65	0.105	1.087	139	10	
18	558,830	551,646	0.00	0.027	0.095	1	0.84	0.116	1.140	129	10	
19	580,137	621,685	0.00	0.027	0.104	1	0.41	0.096	1.111	120	9	
Sat. 20	560,119	461,171	0.00	0.028	0.098	4	1.03		0.942	111	9	
Sun. 21	520,969	449,126	0.00	0.027	0.092	0	0.97		0.986	103	8	
22	563,334	621,817	0.00	0.028	0.092	1	0.84	0.054	0.953	95	8	0.75
23	570,591	545,826	0.00	0.028	0.089	3	0.39	0.104	0.996	86	9	
24	574,284	604,774	0.10	0.029	0.098	1	0.66	0.098	1.015	78	8	
25	584,832	555,327	0.40	0.029	0.118	4	0.60	0.079	1.015	69	9	
26	562,100	548,220	1.10	0.030	0.368	1	0.36	0.098	1.014	60	9	
Sat. 27	523,981	424,520	0.10	0.032	0.198	0	0.87		0.928	50	10	
Sun. 28	514,970	436,302	0.00	0.032	0.141	0	0.87		0.854	41	9	
29	566,502	599,358	0.00	0.032	0.119	3	0.70	0.054	0.847	32	9	0.46
30	604,905	631,955	0.00	0.032	0.110	4	0.41	0.141	0.971	21	11	
Total	16,878,764	16,529,271	2.80	0.816	3.816	104	22.420	2.056	30.477	2,086	282	2.93
Average	562,625	550,976		0.027	0.127	3	0.75	0.098	1.016	75	9.4	0.59

2-2
10/20/25