

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for November 17th, 2025

Water Plant

- 1) Assisting as needed with main St. Sewer and N. Main st water project. Attempting to identify public side of water service line.
- 2) 4th Quarter Haloacidic acid sample taken 11/12/25, waiting on results.
- 3) Lead & Copper sampling completed the 3rd week of September, of the 10 homes tested all were negative for lead.
- 4) Timber sale, no updates.
- 5) I have a price quote thru Ti-sale for a live inspection of the finished water storage tanks at the plant (ROV inspection \$3500 / Diver inspection and sediment removal \$5750).
- 6) Water Meter repairs as needed.

Attachments

- 1) October, water plant flow report.

Respectfully, Neal A. Winkler, Water Plant Operator.

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearewell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Oct-25												
1	621,724	581,295	0.00	0.032	0.105	6	0.60	0.074	1.118	9	12	
2	570,749	567,833	0.00	0.031	0.101	4	0.71	0.068	1.117	<1/150	10	
3	571,279	570,257	0.00	0.030	0.082	3	0.44	0.089	1.128	<3/142	10	
Sat. 4	525,066	428,794	0.00	0.034	0.082	1	0.93		1.070	134	8	
Sun. 5	518,354	436,880	0.00	0.033	0.083	0	0.99		1.087	125	9	
6	558,861	554,395	0.00	0.029	0.084	1	0.92	0.052	1.030	117	8	0.91
7	560,759	549,848	0.00	0.035	0.085	0	0.50	0.082	1.025	108	9	
8	580,272	599,595	1.40	0.033	0.186	1	0.74	0.055	1.036	99	9	
9	595,040	608,160	0.00	0.051	0.179	4	0.76	0.063	0.952	89	10	
10	590,447	598,800	0.00	0.051	0.128	7	0.38	0.072	0.892	79	10	
Sat. 11	544,964	455,125	0.00	0.059	0.106	8	0.68		0.893	69	10	
Sun. 12	490,261	420,471	0.00	0.060	0.096	0	0.68		1.016	59	10	
13	492,882	424,376	0.00	0.062	0.092	0	0.74	0.053	1.118	49	10	0.82
14	536,328	570,395	0.70	0.039	0.129	1	0.52	0.071	1.160	39	10	
15	562,311	588,583	0.00	0.038	0.123	4	0.86	0.043	1.120	29	10	
16	587,477	582,720	0.00	0.042	0.109	8	0.73	0.069	1.033	19	10	
17	576,659	566,297	0.00	0.036	0.099	7	0.43	0.078	1.038	9	10	
Sat. 18	510,688	417,053	0.00	0.031	0.091	4	0.83		0.969	1	8	
Sun. 19	485,711	423,718	0.00	0.032	0.086	0	0.83		0.996	<2/145	8	
20	545,796	591,532	0.20	0.040	0.092	2	0.84	0.054	0.966	137	8	0.51
21	589,387	606,618	0.50	0.037	0.111	7	0.60	0.076	1.038	127	10	
22	600,819	602,212	0.00	0.034	0.106	10	0.27	0.109	1.034	117	10	
23	574,400	526,837	0.30	0.027	0.116	9	0.76	0.061	1.006	107	10	
24	502,698	409,132	0.10	0.036	0.107	1	0.51	0.069	1.087	97	10	
Sat. 25	485,634	431,541	0.10	0.028	0.105	0	1.05		1.187	87	10	
Sun. 26	480,659	421,110	0.01	0.039	0.099	0	1.07		1.092	79	9	
27	525,742	560,949	0.00	0.024	0.094	2	0.93	0.051	1.054	71	8	0.38
28	568,140	598,657	0.00	0.032	0.082	7	0.54	0.112	0.976	63	8	
29	589,988	604,591	0.00	0.033	0.084	9	0.70	0.068	1.068	53	10	
30	609,192	620,546	0.20	0.033	0.081	11	0.84	0.064	1.081	43	10	
31	338,934	510,736	0.90	0.030	0.145	12	0.68	0.074	1.046	33	10	
Total	16,891,221	16,429,056	4.41	1.151	3.268	129	22.060	1.607	32.433	2,048	294	2.62
Average	544,878	529,970		0.037	0.105	4	0.71	0.070	1.046	73	9.5	0.66