

THE VILLAGE OF DOLGEVILLE

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

December 2025 Report

Work

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up
- Water Leaks throughout Village

Water/Sewer

- Cleaned filter #6
- Found curb stop for 713 Brockett Rd and shut off.
- Repaired North Main St Manhole and removed road plate.

- Raised fire hydrant on Spencer St.
- Cleaned up and painted curb box parts
- Used camera for Sewer complaint on South Main St, Cavalli St and Elm St.
- Water shut off on Brockett Rd and Elm St for in house repair- Water is back on at both places.

Streets

- Installed delineators on Cavalli and Mckinnley
- Salting throughout the Village and plowing.
- Cut and prepped a crosswalk at the end of Elm St.
- Painted Cross walk at Elm St
- Cleaned up final leaf piles
- Fixed storm drain on Winton Lane
- Covered sink hole behind car wash and Bever Brook-Advised property owner
- Investigated leaky valve on Winton Lane-fixed
- 2 scrap runs \$164.00 and \$117.00.
- Final green waste run
- Put up Main St decorations
- Pushed up green waste and managed the piles on Hilltop-Rolled leaves etc.
- Put up banners
- Rolled down snow on North Main St to create a hard pack.
- Shoveled side walks

- Put in State Road work permit
- Auction paperwork complete- Had 1 person come to garage to inspect Auction items.
- Set up and broke down light tower for Christmas parade.
- Removed snow from Handicapped parking area at Kinney's

Garage

- "09" Freightliner- Serviced wing slide on head unit, repaired 2 sticky hydraulic controls, installed heated wipers. Truck needs replacement.
- 3500- check engine light is on from the Evap code.
- 12 Freightliner- fixed radiator hose and refilled coolant. Put on heated wipers, fixed hydraulic leak on salter.
- 550- Installed new work lights at the rear, put salter on, repaired a hole in the head plow painted and installed new cutting edges.
- Roller- nothing new
- Loader- discovered a crack in the windshield
- Leaf Picker- nothing new
- Sewer Jet- nothing new
- Skid Steer- nothing new
- Excavator- nothing new

- Monthly Fuel Tank Check and inspections
- Back Hoe- nothing new
- Army Truck/530- sourced glass for door, installed glass and found a broken power steering bracket, removed, welded and replaced. Repaired a loose wire on the plow.
- Fuel tank Gauges- ok
- 60” Mower- nothing new
- Water cart- out of service for the season
- 71” mower- nothing new
- John Deer Tractor- nothing new
- F350-new fuel pump installed, washed inside cab and outside cab.
- Garage cleaning is ongoing.
- Manheim borrowed the lift and is still out.
- New tire machine- no issues
- Cleaning and Organizing water and sewer rooms.
- 602- replaced windshield washer nozzles
- 603- removed lights, decals, console, put stock console in, washed car and put it on Auction.
- First phone in the new system went online as of today.
- Sorting out the fire alarm system with Spectrum.
- Trailer- nothing new
- Village Hall-job is being scheduled for roof. Bench out front put upstairs

Parks

- Center Park- kept driveway open

- Trails- Barriers removed
- Plowe Park- put up road edge markers, Christmas tree put up, had several meetings about power to the gazebo and power was restored. Gazebo is now a separate service from the park which should help with power issues throughout the year. Delivered décor to park.