

VILLAGE OF DOLGEVILLE  
WATER RESOURCE RECOVERY FACILITY  
97 VAN BUREN ST.  
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT NOVEMBER 16, 2025 to DECEMBER 10, 2025

**1. PERMIT COMPLIANCE FOR OCTOBER 2025**

- All limits, levels and monitoring requirements were met except fecal coliform 7-day average. One exceedance on 10/22/25 was due to brief high flows during a rain event at time of sampling.

**2. MAINTENANCE**

- Normal Preventive Maintenance and snow removal.
- Waiting on quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor
- Requested quote from Siewert Equipment for replacement sump pump in Pump Station
- Ordered replacement D.O. probe for portable meter
- Milton CAT 6-month service performed on emergency generator

**3. PRETREATMENT PROGRAM**

Proposed pilot study for additional pretreatment at Gehring Tricot was submitted on October 28, 2025 to the NYSDEC for approval. We received comments back in November and will be meeting to discuss response/pilot revisions/resubmission this week.

**4. MIDGE FLY TREATMENT**

Although we were approved for use of biocide by NYSDEC SPDES permitting group, the Village doesn't have the NYSDEC credentials for legal purchasing or application of the EPA-approved biocide. The product was returned to the manufacturer. The Village will need to be designated as a registered agency and I will go through the process to become a certified technician. The process takes about a year. In the meantime, cold temperatures have made the insects dormant so our microbiology in the tanks has begun to repopulate and recover. I am also looking into a commercial pest control company to apply the biocide in the spring, if needed.

**5. MAIN ST SEWER PROJECT**

See Village Engineer summary