

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT DECEMBER 11, 2025 to JANUARY 15, 2026

1. PERMIT COMPLIANCE FOR NOVEMBER 2025

- All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Normal Preventive Maintenance and snow removal.
- Waiting on quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor
- Replaced sump pump in basement of Pump Station (Influent Building)
- Replacement D.O. probe for portable meter
- Repaired telescopic valve #2 in Primary Tank
- Annual backflow preventer testing completed by Adirondack Mechanical 1/13/26

3. PRETREATMENT PROGRAM

Proposed pilot study for additional pretreatment at Gehring Tricot was submitted on October 28, 2025 to the NYSDEC for approval. On 1/5/26, we received approval and are tentatively scheduled to begin pilot on February 1.

4. NYMIR INSPECTION

One item noted was to add carbon monoxide detectors in boiler room and locations with gas fired overhead heaters. Will order and install.

5. MAIN ST SEWER PROJECT

See Village Engineer summary

5. DIGESTER EMERGENCY PROJECT

-See attached photos and description from Village Engineer. Waiting on quote from Koester Associates.