

To: Village Board

From: Neal A. Winkler, Water Plant Operator.

RE: monthly report

Submitted for December 15th, 2025

Water Plant

- 1) 4th Quarter Haloacidic acid sample taken 11/12/25, sample results were 50.5 bringing our 4-quarter average to 43.75 well below the 60 limits.
 - 2) Timber sale, no updates. Contract states full payment must be made prior to any harvesting or by May 1st, 2026.
 - 3) Tank inspection will be scheduled for some time in the spring when temperatures warm up.
 - 4) State Rt. 29 roadside spring, the letter from DOH came because I called them about the report that was received that the water tested positive for E coli and bacteria. This is a liability for the village.
 - 5) I have been in discussion with DEC about a possible land sale, I will discuss it further at the meeting.
 - 6) Water Meter repairs as needed.
-

Attachments

- 1) November, water plant flow report.

Respectfully, Neal A. Winkler, Water Plant Operator.

	Filter Flow (gpd)	Effluent Flow (gpd)	Precip. (in.)	Filter Bed Turbidity NTU	Raw Water Turbidity NTU	Clearwell (in. below full)	Village CL2 Residual mg/l	Village Turbidity NTU	Entry Point CL2 Residual mg/l	CL2 Tank Weight (lbs)	# CL2 Used/Day	Phosp. Residual (mg/l)
Nov-25												
Sat. 1	316,782	404,316	0.30	0.036	0.216	3	1.04		1.104	23	10	
Sun. 2	454,706	405,842	0.00	0.040	0.176	0	0.94		1.107	12	11	
3	497,454	552,402	0.00	0.047	0.129	4	0.87	0.043	1.071	4	8	0.84
4	555,498	556,695	0.50	0.047	0.136	7	0.47	0.049	1.044	3/142	9	
5	540,720	566,032	0.00	0.047	0.159	8	0.59	0.053	1.017	132	10	
6	547,335	548,555	0.50	0.045	0.151	10	0.69	0.059	0.986	122	10	
7	550,783	528,182	0.00	0.043	0.147	12	0.38	0.061	0.949	112	10	
Sat. 8	485,105	401,052	0.25	0.041	0.127	7	0.80		0.942	102	10	
Sun. 9	437,597	406,943	0.00	0.052	0.121	0	0.76		0.939	92	10	
10	492,759	575,923	0.30	0.040	0.117	3	0.77	0.048	1.001	83	9	0.55
11	553,419	593,320	.25 S	0.041	0.122	11	0.87		0.942	74	9	
12	574,080	573,856	.5 S	0.042	0.109	15	0.53	0.066	0.908	65	9	
13	555,565	523,999	0.00	0.039	0.105	16	0.62	0.077	0.879	56	9	
14	523,757	493,632	0.40	0.380	0.141	12	0.44	0.070	0.976	47	9	
Sat. 15	469,225	405,085	0.00	0.037	0.131	8	0.79		0.987	38	9	
Sun. 16	423,949	416,546	0.50	0.038	0.614	1	0.76		1.013	29	9	
17	447,127	523,431	2" S	0.043	0.413	5	0.83	0.051	1.114	20	9	1.05
18	460,792	513,611	0.00	0.038	0.234	12	0.38	0.061	1.004	10	10	
19	474,087	524,785	0.00	0.045	0.162	24	0.51	0.069	0.938	0	10	
20	572,917	528,915	0.00	0.044	0.128	26	0.68	0.074	0.998	0/140	10	
21	561,822	500,453	0.00	0.042	0.112	17	0.36	0.081	0.899	130	10	
Sat. 22	478,620	370,684	0.00	0.036	0.101	7	0.67		0.971	120	10	
Sun. 23	430,055	379,422	0.00	0.036	0.097	1	0.67		0.941	111	9	
24	511,720	601,392	0.25	0.037	0.104	7	0.80	0.058	0.951	103	8	
25	518,251	453,100	0.00	0.038	0.104	10	0.53	0.069	0.966	94	9	
26	451,700	392,596	0.50	0.034	0.232	2	0.58	0.089	1.014	85	9	
27	425,402	382,821	0.40	0.041	0.235	0	0.90		1.152	75	10	
28	410,943	375,842	2" s	0.039	0.227	0	0.94		1.060	67	8	
Sat. 29	404,004	373,877	2" s	0.038	0.160	0	0.73		0.959	59	8	
Sun. 30	403,285	388,046	3" s	0.045	0.124	0	0.63		0.896	51	8	
Total	14,529,459	14,261,355	3.90	1.571	5.134	228	20.530	1.078	29.728	1,916	279	2.44
Average	484,315	475,379		0.052	0.171	8	0.68	0.063	0.991	68	9.3	0.81