

9
4/26/26

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT MARCH 13, 2026 to APRIL 16, 2026

1. PERMIT COMPLIANCE FOR FEBRUARY 2026

- All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Received quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor, will wait until summer to replace
- Purchase of new sewer cleaner
- Replumbing chlorination/dechlorination system in preparation for disinfection season
- Sinkhole in driveway at Thresher Brook culvert (DPW project)
- Gas bubble blowers/motor need replacing – will be seeking quote from authorized dealer for existing blower
- Driveway sealing entire plant this summer – will be seeking quotes prior to May meeting

3. PRETREATMENT PROGRAM

Proposed pilot study for additional pretreatment at Gehring Tricot was approved on January 5, 2026. Due to heavy I/I in March and early April, we were unable to proceed with pilot. After starting the first week of March, we needed to put it on hold. We are now expecting to resume pilot in May.

4. RATE STUDY

We have attended several online training sessions with Syracuse University-EFC as part of the free Rate Study program that we were selected for. City of Little Falls and Town of Rensselaerville are also participating. Session topics have included budgeting and water/sewer financial planning. Over the next several months, the group will be meeting with B&L to take a closer look at our current rate structure and also several other training sessions. Neal, Amber and I will have a presentation for the Mayor and Board this summer with findings and recommendations for restructuring village water and sewer rates.

5. NEW CYBERSECURITY REQUIREMENTS

On March 26, 2026, the NYSDEC implemented new requirements for cybersecurity at publicly owned wastewater treatment facilities. I have included the NYSDEC letter describing the new annual certification (effective March 2027), operator training and system requirements provided by the NYSDEC. There are grants available to bring systems into compliance with new

regulations. We will need to work with Michael Taylor and Aqualogics to evaluate our current security systems and procedures at the wastewater treatment plant.

6. GIGP WATER METER GRANT

See Village Engineer summary

7. MAIN ST SEWER PROJECT

See Village Engineer summary

8. DIGESTER EMERGENCY PROJECT

Koester Associates will install new grinder recirculation pump. Received update: pump is scheduled to ship 4/24/26. Electrical and installation will occur right after delivery.