

8-1
3/16/26

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD
RE: MONTHLY REPORT JANUARY 16, 2026 to FERUARY 11, 2026

1. PERMIT COMPLIANCE FOR DECEMBER 2025

- All limits, levels and monitoring requirements were met.
- Submitted annual Inflow/Infiltration report to NYSDEC - January 27, 2026
- Submitted annual Water Treatment Chemical form to NYSDEC - January 28, 2026

2. MAINTENANCE

- Normal Preventive Maintenance and snow removal.
- Waiting on quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor
- Operational challenges with freezing issues in several areas of the plant (filterpress drain, gas bubble pressure sensors, primary flight drives, mechanical bar screen ice buildup, etc.)

3. PRETREATMENT PROGRAM

Proposed pilot study for additional pretreatment at Gehring Tricot was approved on January 5, 2026. Due to extreme cold this month we were unable to proceed with pilot as planned in February due to extensive sampling required and sampler lines freezing. We are now scheduled to begin pilot on March 1.

4. NYMIR INSPECTION

Carbon monoxide detectors purchased and installed.

5. MAIN ST SEWER PROJECT

See Village Engineer summary

5. DIGESTER EMERGENCY PROJECT

Koester Associates will install new grinder recirculation pump. The mechanical (piping) and electrical work will be done prior to the pump arrival in April.