

THE VILLAGE OF DOLGEVILLE

To: Village Board of Trustees

From: David Jaquay, DPW Superintendent

May 2026 Report

Work

Current

- Weekly Checks of Sewers
- Daily 811 Requests
- Checking Storm drains
- Continue cleaning Sewer Lines
- Weekly Metal Pick up
- Water Leaks throughout Village

Water/Sewer

- Worked on water shut off list
- Multiple meetings with Carver
- Helped Neil set up back flush filter #3
- Shut down North Main St water line-opened back up
- Cleaned filters

- Exploratory dig for South Main St hydrant
- Flushed North Main St
- Lead and copper dig 111 South Main St-found lead
- Lead and Copper digs on Elm St
- Flushed Fulton County side of State St
- 3 Baker St- waterline removal
- Replaced curb box at 6 South Main St
- Replaced lead gooseneck and complete curb stop at 111 south main st
- Storm drains on Elm St- Rebuilt one and replaced one.
- Gibson St- exercised valve due to weeping
- Blow off Fulton County side
- Shared services with Little Falls to find a water leak
- Jetted sewer main-plugged on N Helmer Ave
- Water complaint 135 North Main St-homeowner reported dirty water inside house, investigated and confirmed.
- Surveyed North Rd
- Water leak S Main St-hydrant lead broken-fixed
- Bled air out of South end of water system
- Water Complaint Stewart St-air found in line-told homeowner to bleed house.
- Found and cleaned 10" valve main st
- Checked valves around Village
- 2- 4 South Helmer small water leak- found while doing a lead and copper dig-fixed.
- Water leak Lamberson and Howard St Ext.- fixed

Streets

- Picking up green waste
- Military Banners put up
- Fixed low spots on Elm and Howard St Ext.
- Culvert repair S. Helmer and Van Buren St ext.- installed drainage and repaired sinking streets.
- Culvert repair at Waste Water treatment plant
- Found one of our rollup signs damaged and repaired
- Spoke with J. Grace about Tree's and potential sewer issue- made aware of where his lines were and that at least one of his lines may interfere.
- Elm St- replaced culvert between storm drains
- Shared services with Little Falls for a dump truck and 1 man for road work in Little Falls.

Garage

- “09” Freightliner- The Truck needs to be replaced-removed plow equipment and put on bumper.
- 3500- oil change
- 12 Freightliner- greased, spreader plate installed

- 550- nothing new
- Roller- changed oil and filters
- Loader- nothing new
- Leaf Picker-nothing new
- Sewer Jet- nothing new
- * Skid Steer-nothing new
- Excavator- changed filters
- Monthly Fuel Tank Check and inspections
- Back Hoe- nothing new
- Army Truck/530- currently out of service due to bad transmission-revisit transmission in the new budget year.
- Fuel tank Gauges- ok
- 60" Mower- Changed oil and filter
- Water cart- nothing new
- 71" mower- changed oil and filter
- John Deer Tractor- changed oil and filter
- F350-nothing new
- Garage cleaning is ongoing.
- Started looking into pricing for a standby generator.
- Manheim borrowed the lift and is still out.
- New tire machine- no issues
- Electric mixer- put together
- Cleaning and Organizing water and sewer rooms.
- 602- nothing new
- Phones up and working, *fire alarm system still requires work.*
- Trailer- nothing new

- Village Hall-Roof. Contacted Lawrence and Sons construction and they are moving ahead.
- Met with Grid to service gas meter at Village Hall
- Made contact again with County HWY about sweeper-came out 5/11/26.

Parks

- Plowe park- Primed flagpole, cleaned, replaced grip tape, replaced spindles around gazebo and reseeded entirety of park laid hay chaff down. Mowing and weed eating. Took second flag pole out to clean.
- Trails- Barriers are being reinstated as trails dry up and access is gained.
- Center Park- Gray building opened, pulled first quote on fencing. Mowing and weed eating.
- Little League Field- Prepped pump and water heater, put online. Found 2 leaking valves and adjusted. Leaking sink and toilet. Shut off sink and adjusted toilet. Mowing and weed eating
- Vet's Park- Water line leaking and service discontinued. Mowing and weed eating
- Luther Park- Washed the Pergola and requested a quote for replacement panels for fence. Switched tables out under pergola. Mowing and weed eating.

