

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT JUNE 12, 2026 to JULY 15, 2026

1. PERMIT COMPLIANCE FOR MAY 2026

All limits, levels and monitoring requirements were met.

2. MAINTENANCE

- Received quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor, will wait until summer to replace (getting updated quote)
- Gas bubble blower #2 – replaced impeller on fan (6/12/26)
- Water supply line to Duperon bar screen, valve – replaced (6/29/26)
- Low water cutoff switch on boiler – replaced by Trojan Energy (7/1/26)
- Warranty work on new chopper pump – replaced mechanical seal (7/13/26)
- Biannual Milton CAT service on emergency generator (7/13/26)

3. CENTER PARK PROJECT

In support of Center Project, coordination has been required with regard to drainage for splash pad and the forcemain from the new pavilion. This included replacing a manhole to tie sewer connections to in Helmer Ave. The existing manhole was in poor condition. Village DPW replaced the manhole 7/6/26.

4. RATE STUDY (no update) – next meeting this week

5. MAIN ST SEWER PROJECT

See Village Engineer summary