

8-1
6/15/26

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT MAY 14, 2026 to JUNE 11, 2026

1. PERMIT COMPLIANCE FOR APRIL 2026

Due to rain-attributable inflow and infiltration (I/I) in April, the plant exceeded the permit limit of 1.0 mgd average flow. The reported flow for April was 1.08 mgd. Report of non-compliance was submitted to NYSDEC. All other limits, levels, and monitoring requirements were met.

2. MAINTENANCE

- Received quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor, will wait until summer to replace
- Driveway sealing by Crane Sealcoating completed 5/30/26
- Several concrete repairs at primary building
- Collection system repair on Dolge Ave. by DPW

3. RATE STUDY (no update)

4. MAIN ST SEWER PROJECT

See Village Engineer summary