

8-1
5/18/26

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT APRIL 17, 2026 to MAY 13, 2026

1. PERMIT COMPLIANCE FOR MARCH 2026

SPDES permit requires 85% removal for BOD and TSS. Due to rain-attributed inflow and infiltration (I/I) in March, the plant did not meet the removal efficiency and also exceeded the permit limit of 1.0 mgd average flow. The plant removed 80% BOD and 77% TSS and had an average flow of 1.26mgd. Report of non-compliance was submitted to NYSDEC.

2. MAINTENANCE

- Received quote from Avanti Controls, replacement thermostat and heat trace for mechanical bar screen/compactor, will wait until summer to replace
- Sinkhole in driveway at Thresher Brook culvert (DPW project) – repair complete
- Driveway sealing entire plant this summer – one quote received, PO submitted for Board signature for Crane Sealcoating
- Annual chlorinator/sulfonator service completed by Kleen H2O and required the replacement of one sulfonator.
- New digester recirculation pump was installed and is operational – 5/14/2026

3. PROPOSAL FOR ENGINEERING SERVICES

Engineering services proposal for Barton and Loguidice for sanitary sewer design related to the NYSDOT Rt. 29 Bridge project for Board approval is forthcoming. Further discussion has taken place in the field with NYSDOT representatives regarding the future East Canada Creek forcemain and existing gravity sewer on the east side of the bridge in the Dolge Ave/Rt. 29 intersection.

4. PRETREATMENT PROGRAM

NYSDEC-approved pilot study for additional pretreatment at Gehring Tricot began again May 4 after stopping due to high flows at WWTP during spring thaw/rains.

5. RATE STUDY (no update)

We have attended several online training sessions with Syracuse University-EFC as part of the free Rate Study program that we were selected for. Neal, Amber and I will have a presentation for the Mayor and Board this summer with findings and recommendations for restructuring village water and sewer rates.

6. NEW CYBERSECURITY REQUIREMENTS (no update)

7. GIGP WATER METER GRANT

See Village Engineer summary

8. MAIN ST SEWER PROJECT

See Village Engineer summary

9. DIGESTER EMERGENCY PROJECT - COMPLETE