

6-1
9/21/26

VILLAGE OF DOLGEVILLE
WATER RESOURCE RECOVERY FACILITY
97 VAN BUREN ST.
DOLGEVILLE, N.Y. 13329

ATTN: DOLGEVILLE VILLAGE BOARD

RE: MONTHLY REPORT AUGUST 14, 2026 to SEPTEMBER 17, 2026

1. PERMIT COMPLIANCE

- All limits, levels and monitoring requirements were met during July monitoring period
- Annual Fast Report on Significant Industrial Users submitted to NYSDEC 8/18/26
- Annual Mercury Minimization Report submitted to NYSDEC 8/18/26

2. MAINTENANCE

- Normal maintenance on equipment
- Vaughn Pump representative and Koester Associate technician replaced new pump seal (#3) – 8/24/26
- Primary settling tank #2 sprockets, flights, and flight chain replacement work is tentatively to begin 9/21.

3. RATE STUDY

See Village Engineer summary

4. MAIN ST SEWER PROJECT

See Village Engineer summary

5. NYSDOT ROUTE 29 BRIDGE PROJECT

Department heads and B&L met on 8/27/26 with NYSDOT Regional Utilities Engineer to discuss village-owned water and sewer utilities within the Route 29 Bridge project limits.

Sewer infrastructure work that will be part of the NYSDOT project includes: several manhole-to-manhole sections of sanitary sewer CIPP lining, replacement/realignment of sanitary sewers and manholes within the new intersection alignment as well as the installation of a forcemain pipe that will be hung on the bridge. The forcemain will be put in place to prepare for a future Village project that will replace the existing siphon under East Canada Creek with a pump station and forcemain. NYSDOT will pay for the sanitary sewer work for this project.

Existing water infrastructure within the project limits will also be replaced. Additionally, the NYSDOT is preparing an estimate for a betterment to add a new water line that will be hung on the new bridge. The existing watermain that serves the homes and hydrants directly across the bridge is approximately 130 years old and runs under the East Canada Creek. The second waterline would ensure continued water and fire suppression should that existing line fail. If the Village decides to move forward with the water betterment (the section to be hung on the bridge including insulation and hangars), the Village will need to enter an agreement for the

betterment work and make funds available no later than January 21, 2027. The estimate is expected sometime next week and our next meeting will be on October 1.

6. PILOT STUDY

The final report documenting the findings of the pilot study for additional pretreatment at Gehring Tricot was sent for NYSDEC review on 9/10/26.