

To: Village Board

From: Clay Laubach, Water Plant Operator.

RE: monthly report

Submitted for July 20, 2026

Water Plant

- 1) Timber harvesting has been completed, and clean up is continuing.
 - 2) Third quarter Disinfection By-Products will be collected in August 2026
 - 3) DPW crew has completed several water main and lateral repairs.
 - 4) Continuing to clean and back flush filters as needed. Hoping longer back flushing times will improve filter performance. I included a Filter Bed Performance Chart that shows the effect of flow / head loss when a filter bed has been backwashed and cleaned. -Reference Bed #5- backflushed on 6-8-2026
 - 5) Bed #4 will be backflushed after the reservoir cleanout
 - 6) Reservoir cleanout will begin the week of 7-27-2026
 - 7) DEC land sale, no new updates.
 - 8) Water Meters- working with the team to help keep it moving forward.
 - 9) Continuing to work with water line issues on Main st. sewer project. The hydrant at the corner of Spofford and Main St. Has been relocated on 6-8-2026.
 - 10) Turbidity meters at the plant will need future replacement as two of the three are no longer supported by the manufacturer. We're looking at analyzers from Avanti Control Systems and TiSales.
-

Attachments

- 1) June 2026 water plant flow report.

Respectfully, Clay Laubach, Water Plant Operator.